



SYSTEM DESCRIPTION

Orientation: Wall
Trade / Type: Plumbing / Hydraulic / Active Fire
Service: UPVC
Substrate: Concrete wall
Min Substrate Thickness (mm): 100
Sealant Depth (mm): 10
Sealant Fillet (mm): -
Wrap Length (mm): -
FRL / FRR: -/120/120

FIRE STOPPING INFORMATION

BOSS MaxiCollar™	-
BOSS FireMastic-300™	-
-	-
APERTURE (MM)	ANNULAR GAP (MM)
-	10.0

ADDITIONAL INFORMATION

SERVICE SIZE & DETAILS

Up to 110 mm uPVC pipe with 4.2 mm maximum wall thickness. Sealant 10.0 mm deep in 10.0 mm annular gap both sides. 110 mm BOSS MaxiCollar™ installed on both sides.



Phone AU	1300 502 677
Phone NZ	0800 502 677
Web	bossfire.com
SUPPORTING INFORMATION	
Reference Standard	AS 1530.4:2014
Supplementary Standard	AS 4072.1-2005
Report Reference	WF FAS 210203
Drawing Number	BF-2660.4
Date of Issue	12/06/25
Rev	01

LIMITATION: BOSS Passive Fire provides this technical information in good faith and to the best of its knowledge. The information was deemed correct at the time of publication. BOSS Passive Fire reserves the right to amend this document without notice if new data arises. This guide does not guarantee compliance for all applications. Each project may have specific requirements that need careful investigation. Ensure you read and understand the appropriate certification and seek acceptance from the Certifying Authority before installation. For updates, contact BOSS Technical Services on +61 2 9524-4040. Copyright© 2025 BOSS Passive Fire Pty Ltd. All rights reserved.