



SYSTEM DESCRIPTION

Orientation: Wall
Trade / Type: Electrical
Service: Fire Alarm
Substrate: 2 layers BOSS Batt - Pattress fitted either side
Min Substrate Thickness (mm): 75
Sealant Depth (mm): 25
Sealant Fillet (mm): 0
Wrap Length (mm): -
FRL / FRR: -/120/120

FIRE STOPPING INFORMATION

BOSS FireMastic-HPE™	-
-	-
-	-
APERTURE (MM)	ANNULAR GAP (MM)
20	-

ADDITIONAL INFORMATION

SERVICE SIZE & DETAILS

Up to 4 x ELV (extra low voltage) Fire Alarm cables. Sealant to a depth of 25 mm in annular gap and finished flush.



Phone AU	1300 502 677
Phone NZ	0800 502 677
Web	bossfire.com

SUPPORTING INFORMATION

Reference Standard	AS 1530.4:2014
Supplementary Standard	AS 4072.1-2005
Report Reference	WF FAS 190335
Drawing Number	BF-2012.14
Date of Issue	26/11/24
Rev	01

LIMITATION
BOSS Passive Fire Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Passive Fire attention relating to the fire resistance or performance of the product described, BOSS Passive Fire Pty Ltd reserve the right to amend this document or drawing. BOSS Passive Fire strive to constantly improve and develop products so this information may change without notice. The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591 Copyright© 2024 BOSS Passive Fire Pty Ltd. All rights reserved.