



SYSTEM DESCRIPTION	FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS
Orientation: Wall	BOSS FireMastic-HPE™	-	Up to 4 x 0.75 mm ² TPS (Fire Alarm) Power Cables. Sealant to a depth of 25 mm in annular gap and finished flush both sides.
Trade / Type: Electrical	-	-	
Service: Fire Alarm	-	-	
Substrate: Concrete wall	APERTURE (MM)	ANNULAR GAP (MM)	
Min Substrate Thickness (mm): 116	30	-	
Sealant Depth (mm): 25	ADDITIONAL INFORMATION		
Sealant Fillet (mm): 0			
Wrap Length (mm): -			
FRL / FRR: -/120/120			

LIMITATION
 BOSS Passive Fire Pty Ltd has provided the above technical information in good faith and to the best of its knowledge. This information was deemed to be correct at the time of publication. Should any data come to BOSS Passive Fire attention relating to the fire resistance or performance of the product described, BOSS Passive Fire Pty Ltd reserve the right to amend this document or drawing. BOSS Passive Fire strive to constantly improve and develop products so this information may change without notice. The information contained herein has been developed as a guide only and it does not constitute a guarantee of compliance of all applications. Each project and/or application may have specific requirements and you should investigate these carefully. Ensure that you have read and understood the appropriate certification relative to your needs, and ensure you seek acceptance from the Certifying Authority or compliance inspector before installation. For updates on the range of BOSS Fire® certification please contact BOSS Technical Services. +61 2 9531 8591 Copyright© 2024 BOSS Passive Fire Pty Ltd. All rights reserved.

Phone AU	1300 502 677
Phone NZ	0800 502 677
Web	bossfire.com
SUPPORTING INFORMATION	
Reference Standard	AS 1530.4:2014
Supplementary Standard	AS 4072.1-2005
Report Reference	WF FAS 190335
Drawing Number	BF-2013.4
Date of Issue	26/11/24
Rev	01