



SYSTEM DESCRIPTION	
Orientation:	Wall
Trade / Type:	Electrical
Service:	TPS
Substrate:	Single Layer Fire Rated Plasterboard System
Min Substrate Thickness (mm):	90
Sealant Depth (mm):	13
Sealant Fillet (mm):	0
Wrap Length (mm):	-
FRL / FRR:	-/60/60

FIRE STOPPING INFORMATION	
BOSS FireMastic-HPE™	-
-	-
-	-
APERTURE (mm)	**ANNULAR GAP (mm)**
-	10
ADDITIONAL INFORMATION	
-	

SERVICE SIZE & DETAILS

Bundle of 8 x 2.5 mm², 2C+E TPS Power Cables. Sealant to depth of plasterboard in 10 mm annular gap finished flush.

SUPPORTING INFORMATION			
Reference Standard:	AS 1530.4:2014		
Supplementary Standard:	AS 4072.1-2005		
Report Reference:	WF FAS 190335		
Drawing Number:	BF-2024.1		
Date:	03/12/24	**Rev:**	01

IMPORTANT: This drawing is provided as a guide only and does not guarentee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.