





SYSTEM DESCRIPTION		FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS	SUPPORTING INFORMATION				
Orientation:	Wall	BOSS FireMastic-HPE™	-	Up to 6 x 2.5 mm², 2C+E TPS Power Cables. Sealant to depth of plasterboard in 57 mm aperture finished flush.	Reference Standard:		AS 1530.4:2014		
Trade / Type:	Electrical	-	-		Supplementary Standard:		AS 4072.1-2005		
Service:	TPS	-	-		Report Reference:		WF FAS 190335		
Substrate:	2 layers BOSS Batt - Friction fitted	APERTURE (mm)	ANNULAR GAP (mm)		Drawing Number:		BF-2025.13		
Min Substrate Thickness (mm):	116	57	-		Date:	03/12/24	Rev:	01	
Sealant Depth (mm):	26	ADDITIONAL INFORMATION							
Sealant Fillet (mm):	0	-							
Wrap Length (mm):	-								
FRL / FRR:	-/120/120								

IMPORTANT: This drawing is provided as a guide only and does not guarantee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.