



SYSTEM DESCRIPTION		FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS	SUPPORTING INFORMATION			
Orientation:	Wall	BOSS FireMastic-HPE™	-	Up to 6 x 2.5 mm², 2C+E TPS Power Cables. Sealant to a depth of 25 mm and finished flush both sides.	**Reference Standard:**	AS 1530.4:2014		
Trade / Type:	Electrical	-	-		**Supplementary Standard:**	AS 4072.1-2005		
Service:	TPS	-	-		**Report Reference:**	WF FAS 190335		
Substrate:	2 layers BOSS Batt - Friction fitted	**APERTURE (mm)**	**ANNULAR GAP (mm)**		**Drawing Number:**	BF-2028.13		
Min Substrate Thickness (mm):	75	57	-		**Date:**	03/12/24	**Rev:**	01
Sealant Depth (mm):	25	**ADDITIONAL INFORMATION**						
Sealant Fillet (mm):	0	-						
Wrap Length (mm):	-							
FRL / FRR:	-/120/120							

IMPORTANT: This drawing is provided as a guide only and does not guarentee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.