





SYSTEM DESCRIPTION		FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS	SUPPORTING INFORMATION			
Orientation:	Wall	BOSS FireMastic-HPE™	-	Up to 100 mm copper pipe with 50 mm thick stonewool insulation. Insulation wrapping is extended 600 mm on both sides. Sealant 26 mm deep in annular gap and finished with 35 mm x 35 mm fillet on both sides.	Reference Standard:		AS 1530.4:2014	
Trade / Type:	Plumbing / Hydraulic / Active Fire	Stonewool insulation	-		Supplementary Standard:		AS 4072.1-2005	
Service:	Insulated Copper Pipes	-	-		Report Reference:		WF FAS 190335	
Substrate:	Concrete wall	APERTURE (mm)	ANNULAR GAP (mm)		Drawing Number:		BF-2069.4	
Min Substrate Thickness (mm):	135	224	-		Date:		12/12/24	Rev:
Sealant Depth (mm):	16	ADDITIONAL INFORMATION						01
Sealant Fillet (mm):	35							
Wrap Length (mm):	600							
FRL / FRR:	-/120/120							

IMPORTANT: This drawing is provided as a guide only and does not guarantee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.