



SYSTEM DESCRIPTION	
Orientation:	Wall
Trade / Type:	Plumbing / Hydraulic / Active Fire
Service:	PEX
Substrate:	2 layers BOSS Batt - Friction fitted
Min Substrate Thickness (mm):	144.0
Sealant Depth (mm):	25.0
Sealant Fillet (mm):	0.0
Wrap Length (mm):	-
FRL / FRR:	-/120/60

FIRE STOPPING INFORMATION	
BOSS MaxiCollar™	-
BOSS FireMastic-HPE™	-
-	-
APERTURE (mm)	**ANNULAR GAP (mm)**
32	3.5
ADDITIONAL INFORMATION	
-	

SERVICE SIZE & DETAILS

Up to 25 mm PE-Xb pipe installed with BOSS 32 mm MaxiCollar on both sides. Sealant 25 mm deep to fill the gap between the collar and pipe on both sides.

SUPPORTING INFORMATION			
Reference Standard:	AS 1530.4:2014		
Supplementary Standard:	AS 4072.1-2005		
Report Reference:	WF FAS 190335		
Drawing Number:	BF-2132.13		
Date:	06/11/25	**Rev:**	01

IMPORTANT: This drawing is provided as a guide only and does not guarentee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.