



SYSTEM DESCRIPTION	
Orientation:	Wall
Trade / Type:	Plumbing / Hydraulic / Active Fire
Service:	PEX-AL
Substrate:	2 layers BOSS Batt - Friction fitted
Min Substrate Thickness (mm):	75
Sealant Depth (mm):	20
Sealant Fillet (mm):	20
Wrap Length (mm):	-
FRL / FRR:	-/120/120

FIRE STOPPING INFORMATION	
BOSS FireMastic-HPE™	-
-	-
-	-
APERTURE (mm)	**ANNULAR GAP (mm)**
48	11.5
ADDITIONAL INFORMATION	
-	

SERVICE SIZE & DETAILS

Up to 20 mm PEX/AL/PEX pipe. Sealant to depth of 20 mm in annular gap both sides, with 20 mm x 20 mm fillet both sides.

SUPPORTING INFORMATION			
Reference Standard:	AS 1530.4:2014		
Supplementary Standard:	AS 4072.1-2005		
Report Reference:	WF FAS 190335		
Drawing Number:	BF-2155.13		
Date:	13/01/25	**Rev:**	01

IMPORTANT: This drawing is provided as a guide only and does not guarentee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.