





BUILD UP DETAILS

*Localised thickening to be fixed and sealed to substrate using appropriate methods relevant to the substrate and build up material.

*To achieve the necessary thickness and FRL rating of the originally tested substrate, the separating element can be built-up on one or both sides by using BOSS Batts, fire-rated plasterboard, calcium silicate board, or Shaftliner board.

SYSTEM DESCRIPTION		FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS	SUPPORTING INFORMATION			
Orientation:	Wall	BOSS FireMastic-300™	-	Cable bundle -Up to 2.5mm² 2C+E Power Cable -Up to 3 x 6mm² 3C+E Power Cables -Up to 8 x 16mm² 3C+E Power Cables FireMastic-300™ Sealant installed 16mm deep in annular gap. For annular gaps larger than 20mm and up to 50 mm, a mineral wool backing rod must be used to back the applied sealant. The service is to be finished with a 50 mm x 50 mm fillet both sides. 600mm of Thermal Defence Wrap each side of the wall.	Reference Standard:		AS 1530.4:2014	
Trade / Type:	Electrical	BOSS Thermal Defence	-		Supplementary Standard:		AS 4072.1-2005	
Service:	Multi Core / Orange Circular / Mains	-	-		Report Reference:		WF FAS 200332	
Substrate:	Speedpanel / Korok with Buildup	APERTURE (mm)	ANNULAR GAP (mm)		Drawing Number:		BF-2453.16	
Min Substrate Thickness (mm):	96	-	20 - 50		Date:	12/05/25	Rev:	01
Sealant Depth (mm):	16	ADDITIONAL INFORMATION						
Sealant Fillet (mm):	50							
Wrap Length (mm):	600							
FRL / FRR:	-/90/90							

IMPORTANT: This drawing is provided as a guide only and does not guarantee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.