





SYSTEM DESCRIPTION		FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS	SUPPORTING INFORMATION			
Orientation:	Wall	BOSS FireSilicone-EMA™	-	32mm - 54mm Copper pipe with maximum wall thickness of 1.0mm. 30 - 50 mm lagging. UniWrap™ installed over the Thermobreak lagging with multiple layers, flush on both sides to a minimum 40mm depth. FireSilicone-EMA™ Sealant installed in annular gap flush on both sides. 250mm of Thermal Defence Wrap each side of the wall.	Reference Standard:		AS 1530.4:2014	
Trade / Type:	Plumbing / Hydraulic / Active Fire	BOSS Thermal Defence	-		Supplementary Standard:		AS 4072.1-2005	
Service:	Copper Pipes	BOSS UniWrap™	-		Report Reference:		WF FAS 200332	
Substrate:	Double Layer Fire Rated Plasterboard System	APERTURE (mm)	ANNULAR GAP (mm)		Drawing Number:		BF-2494.2	
Min Substrate Thickness (mm):	96	-	Up to 20		Date:	02/05/25	Rev:	01
Sealant Depth (mm):	16	ADDITIONAL INFORMATION						
Sealant Fillet (mm):	0							
Wrap Length (mm):	250							
FRL / FRR:	-/90/90							

IMPORTANT: This drawing is provided as a guide only and does not guarantee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.