



25mm Shaftliner
13mm Fire Rated Plasterboard
BOSS FireMastic-300™
BOSS MaxiCollar™
Up to 32mm PEX-AL-PEX Pipe



SYSTEM DESCRIPTION		FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS	SUPPORTING INFORMATION				
Orientation:	Wall	BOSS MaxiCollar™	-		Up to 32 mm PEX-AL-PEX pipe with 3.0 mm maximum wall thickness. Sealant 13.0 mm deep in 3.0 mm - 4.0 mm annular gap both sides. 32 mm BOSS MaxiCollar™ installed on both sides.	Reference Standard:		AS 1530.4:2014	
Trade / Type:	Plumbing / Hydraulic / Active Fire	BOSS FireMastic-HPE™	-			Supplementary Standard:		AS 4072.1-2005	
Service:	PEX-AL	-	-			Report Reference:		WF FAS 210203	
Substrate:	Shaftliner	APERTURE (mm)	ANNULAR GAP (mm)			Drawing Number:		BF-2689.12	
Min Substrate Thickness (mm):	118	-	3 - 4.0			Date:	01/07/25	Rev:	01
Sealant Depth (mm):	13.0	ADDITIONAL INFORMATION							
Sealant Fillet (mm):	-	-							
Wrap Length (mm):	-								
FRL / FRR:	-/60/45								

IMPORTANT: This drawing is provided as a guide only and does not guarantee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.