





SYSTEM DESCRIPTION		FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS	SUPPORTING INFORMATION				
Orientation:	Wall	BOSS MaxiCollar™	-		Up to 125 mm PE pipe with 3.1 - 11.4 mm wall thickness. Sealant installed around service 10 mm deep in 10 mm annular gap finished flush both sides. The system includes a 125 mm BOSS MaxiCollar™ installed to both sides. Installed in min 100 mm thick walls.	Reference Standard:		AS 1530.4:2014	
Trade / Type:	Plumbing / Hydraulic / Active Fire	BOSS FireMastic-300™	-			Supplementary Standard:		AS 4072.1-2005	
Service:	PE	-	-			Report Reference:		WF FAS 210203	
Substrate:	Single Layer Fire Rated Plasterboard System	APERTURE (mm)	ANNULAR GAP (mm)			Drawing Number:		BF-2937.1	
Min Substrate Thickness (mm):	100	-	10			Date:	07/08/25	Rev:	01
Sealant Depth (mm):	10	ADDITIONAL INFORMATION							
Sealant Fillet (mm):	-								
Wrap Length (mm):	-								
FRL / FRR:	-/90/90								

IMPORTANT: This drawing is provided as a guide only and does not guarantee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.