





SYSTEM DESCRIPTION		FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS	SUPPORTING INFORMATION				
Orientation:	Wall	BOSS MaxiCollar™	-	Up to 33.4 mm cPVC pipe with 2.6 mm wall thickness. The system includes a 40 mm BOSS MaxiCollar™ installed to both sides.	Reference Standard:		AS 1530.4:2014		
Trade / Type:	Plumbing / Hydraulic / Active Fire	-	-		Supplementary Standard:		AS 4072.1-2005		
Service:	CPVC	-	-		Report Reference:		WF FAS 210203		
Substrate:	Single Layer Fire Rated Plasterboard System	APERTURE (mm)	ANNULAR GAP (mm)		Drawing Number:		BF-3089.1		
Min Substrate Thickness (mm):	116	-	0.8		Date:	04/09/25	Rev:	01	
Sealant Depth (mm):	-	ADDITIONAL INFORMATION							
Sealant Fillet (mm):	-	-							
Wrap Length (mm):	-								
FRL / FRR:	-/120/120								

IMPORTANT: This drawing is provided as a guide only and does not guarantee compliance for every application. Confirm that the supporting certification is applicable to your specific construction details and obtain acceptance from the relevant Certifying Authority before installation. BOSS Passive Fire reserves the right to amend this document without notice.