




SYSTEM DESCRIPTION		FIRE STOPPING INFORMATION		SERVICE SIZE & DETAILS	SUPPORTING INFORMATION			
Orientation:	Wall	BOSS FireStrip-ALX™	-	29 mm wide × 12 mm deep BOSS FireStrip-ALX™ linear gap seal friction fitted within a 25 mm wide vertical linear gap, positioned nominal 50 mm from the unexposed face of the wall system.	Reference Standard:		AS 1530.4:2014	
Trade / Type:	Construction (Linear Gaps / Blank Seals)	-	-		Supplementary Standard:		AS 4072.1-2005	
Service:	-	-	-		Report Reference:		FAS190039 R2.0	
Substrate:	Concrete wall	APERTURE (mm)	ANNULAR GAP (mm)		Drawing Number:		BF-3407.4	
Min Substrate Thickness (mm):	250	25	-		Date:	03/09/25	Rev:	01
Sealant Depth (mm):	-	ADDITIONAL INFORMATION						
Sealant Fillet (mm):	-							
Wrap Length (mm):	-							
FRL / FRR:	-/120/-							